

SILVER LAKE WATER & SEWER DISTRICT DISTRICT STANDARDS 2010

Major Modifications to 2010 Standards Include:

GENERAL DRAFTING STANDARDS

- Developer will be responsible for an “As-Built Survey” and will provide electronic files to the District prior to project acceptance.

WATER SYSTEMS

- Water meters 2 inch and smaller shall be installed by the District.
- Locking valve covers may be required in traffic areas.

SANITARY SYSTEMS

- Individual side sewer connections to exiting sewers in rights-of-way shall require a Developer Extension Agreement prior to installation.
- C900 PVC is allowed for deep sewer.
- Side sewer tees shall match the main line pipe material.

SEWAGE LIFT STATIONS

- Field vibration testing of pumps is now required.

CROSS-CONNECTION CONTROL

- This Section incorporates the District’s cross-connection protection requirements as its own section.

DETAILS

- Sewer manhole frames and covers detail added.
- Revised electrical rack design for lift stations added.

Additional modifications have been made throughout the 2010 Developer Standards. The Developer shall review the entire document.