



MINIMUM ENCASEMENT DIAMETER	
CARRIER DIA.(IN.)	ENCASEMENT DIA.(IN.)
6	14
8	18
10	21.5
12	23
16	30

NOTES:

1. CONTRACTOR TO VERIFY LINE AND GRADE PRIOR TO FILLING VOIDS WITH SAND.
2. CARRIER PIPE WITHIN THE LENGTH OF THE ENCASEMENT PIPE SHALL HAVE RESTRAINED JOINTS.
3. REGULATORY AGENCY REQUIREMENTS SHALL SUPERSEDE DISTRICT STANDARDS IF MORE STRINGENT.
4. CASING PIPE SHALL BE SCHEDULE 40 STEEL PIPE, WELDED JOINT, AND MINIMUM YIELD STRENGTH (F_y) OF 35 KSI.

ENCASEMENT/CARRIER PIPES

**Silver Lake Water and Sewer District
STANDARD DETAILS**