



NOTES:

1. NO SPLICES IN 2" COPPER PIPE ALLOWED.
2. SERVICE FROM METER BOX TO STRUCTURE BY PROPERTY OWNER.
3. INDIVIDUAL SERVICES REQUIRED FOR EACH STRUCTURE.
4. 2-INCH METER SETTER (WITH ADAPTERS IF 1 1/2-INCH METER USED), NEPTUNE OR RADIO READ SENSUS METER WITH SENSUS AMR MXU UNIT READING 100 CUBIC FEET SHALL BE FURNISHED BY THE DEVELOPER. SETTER - A.Y. McDONALD 30B7-WWFF 775 OR MUELLER B-2427. DRILL 2" DIAMETER HOLE IN LID FOR MXU DEVICE.
5. BERG VAULT CO. OF WASH NO. 2 CONCRETE METER BOX OR MID STATES PLASTICS MSBCF 1730-12 COMPOSITE METER BOX. BOX SHALL BE H-20 LOAD RATED WHERE REQUIRED.
6. ESMT PROVIDED TO SLWSD AROUND METERS LOCATED OUTSIDE R/W.
7. ALL SERVICES SHALL HAVE WASHINGTON STATE APPROVED RPBA FOR BACKFLOW PREVENTION LOCATED IMMEDIATELY BEHIND METER. CONFIRM LOCATION OF ASSEMBLY WITH DISTRICT. INITIAL AND ANNUAL TESTING REQUIRED AND SUBMITTAL OF TEST RESULTS TO SLWSD FOR CONFIRMATION. MULTIFAMILY ALLOWED TO USE DCVA IN LIEU OF RPBA.

2" WATER SERVICE

Silver Lake Water and Sewer District
STANDARD DETAILS