



NOTES:

1. OR 3' FROM BACK OF CURB
2. PROVIDE 8' OF CULVERT AND COVER, 12" MIN. DIA. OR EQUAL IN SIZE TO ADJACENT DITCH CROSSINGS. PIPE TO COUNTY, STATE OR CITY STANDARDS AS APPLICABLE.
3. PROVIDE MIN. 3'-0" CLEARANCE AND LEVEL AREA AROUND HYDRANT
4. PAINT FIRE HYDRANT WITH TWO COATS KELLY MOORE 6100-516 YELLOW AND TOP OF HYDRANT COLOR DETERMINED BY SERVICE LEVEL GPM.
 - # 213 SAFETY BLUE-SERVICE LEVEL 1500 GPM OR GREATER
 - # 815 SAFETY GREEN-SERVICE LEVEL 1000 TO 1499 GPM
5. STENCIL FOOTAGE TO VALVE ON HYDRANT UNDER PORT FACING GV
6. REMOVE ALL CHAINS FOR FIRE HYDRANT CAPS
7. ACCEPTABLE HYDRANTS: CLOW MEDALLION, M&H STYLE 929, MUELLER CENTURION, WATEROUS PACER
8. INSTALL BLUE FIRE HYDRANT REFLECTOR. OFFSET 1 FOOT FROM ROAD CENTERLINE

FIRE HYDRANT ASSEMBLY

Silver Lake Water and Sewer District
STANDARD DETAILS