



NOTES:

1. IN-LINE VALVE(S) IN EXISTING SYSTEM MAY BE REQUIRED BY THE DISTRICT AT NEW INTERTIE LOCATIONS. VALVE(S) ARE NOT SHOWN ABOVE FOR CLARITY.
2. MAXIMUM SPACES BETWEEN PIPES SHALL BE 1/4-INCH. IF A SINGLE SLEEVE IS USED, THE MAXIMUM SPACER WIDTH IS 2-INCHES.
3. CONNECTIONS NOT ALLOWED ON FRIDAYS, HOLIDAYS, DAY BEFORE HOLIDAYS, OR WEEKENDS.

CUT IN CONNECTION

Silver Lake Water and Sewer District
STANDARD DETAILS